



AC 117

INSTYTUT ENERGETYKI

Instytut Badawczy

01-330 Warszawa, ul. Mory 8

tel. +48 22 34 51 299

fax. +48 22 836 63 63

instytut.energetyki@ien.com.pl

CERTIFICATE OF CONFORMITY

No. 043/2020

Issue No. 01 from 2020.05.28

*Name and address of
the Certificate Holder:*

ERKO sp. z o.o. sp. k.
Ks Jana Hanowskiego 7 Str.,
11-042 Jonkowo, Poland

Name of the product:

Family of mechanical terminal lugs up to 36 kV

Type:

KSSP

Manufacturer:

ERKO sp. z o.o. sp. k.
Ks Jana Hanowskiego 7 Str., 11-042 Jonkowo, Poland

Production plant:

ERKO sp. z o.o. sp. k., Czeluśnica 80 (k. Jasła),
38-204 Tarnowiec, Poland

*Parameters and
application of product:*

According to appendix
Terminal lugs designed for terminating power cables in medium
voltage networks.

*The product meets
requirements of the:*

IEC 61238-1-3:2018 (ed. 1.0)

*According to the
report made by:*

Instytut Energetyki

*Number of the
evaluation report:*

DZC/25c/E/2020-4

Period of validity:

from 28th of May 2020 until 27th of May 2023

The right to use the certificate of conformity within its validity period applies only to:

- these copies that meet the requirements specified above and have the same characteristics (parameters) as the model / product samples submitted for testing,
- certificate holder or his authorized representative.

The list of evidenced parameters is included in the appendices to the certificate of conformity.

Number of appendices: 1

THE SYSTEM OF PRODUCT CERTIFICATION PC_1a (Program 1 acc. to PN-EN ISO/IEC 17067:2014-01)
(product parameters confirmed by type tests)



DIRECTOR OF
INSTYTUT ENERGETYKI

dr hab. inż. Tomasz Gałka prof. IEn

Warsaw, 2020.05.28



AC 117

APPENDIX TO THE CERTIFICATE OF CONFORMITY
No. 043/2020
Issue No. 01 of 2020.05.28

LIST OF EVIDENCED PARAMETERS

Element type	KSSP 12-1695 16 - 95	KSSP 12-50150 50 - 150	KSSP 12-95240 95 - 240
Class	A 1		
Shape of Al cables /cross-section [mm ²]	rm, rmc, sm / 16 ÷ 240		
Shape of Cu cables /cross-section [mm ²]	class 5 / 70 ⁷⁾	-----	
Initial scatter $\delta^{1)}$	$\leq 0,30$		
Mean scatter $\beta^{2)}$	$\leq 0,30$		
Resistance factor ratio $\lambda^{3)}$	$\leq 2,0$		
Change in resistance factor $D^{4)}$	$\leq 0,15$		
Maximum temperature $\theta_{max}^{5)}$	$\leq \theta_{ref}$		
Permissible tensile force [N]	$\leq 40xA^{6)}$ Al $\leq 60xA^{6)}$ Cu ⁷⁾		

NOTES:

- 1) ¹⁾ The average value of the resistance factors of six connectors before the first heating cycle.
- 2) ²⁾ The average value of the resistance factors of six connectors calculated from last 11 measurements readings. It specifies if all connectors of given type are characterized by similar changes in resistance during the heat cycles.
- 3) ³⁾ Resistance factor ratio of tested connector during the heat cycle test in relation to the initial resistance factor.
- 4) ⁴⁾ The value specifies the size of the resistance factor change based on last 11 measurements readings.
- 5) ⁵⁾ Temperature of the connector referenced to the temperature of the reference section.
- 6) ⁶⁾ Nominal cross-sectional area.
- 7) ⁷⁾ Concerns KSSP 12-1695

